



NOTES:

1. ALL OPENINGS SHALL BE SEALED WITH LINK SEAL OR APPROVED BOOT STYLE SEAL.
2. AFTER THE MANHOLE IS PLACED AND THE REQUIRED INSPECTIONS ARE COMPLETED, THE EXISTING MAIN SHALL BE CUT AWAY AND THE FLOW CHANNEL GROUTED.
3. SEE PRECAST CONCRETE MANHOLE DETAIL FOR FRAME AND COVER SPECIFICATIONS.

NEW MANHOLE OVER EXISTING MAIN